



Seth Karlinsky
P.O. Box 546
Chilmark, MA 02535
Phone: 508-645-9310
Cell: 508-455-8615
smithpropertymv@gmail.com
sethkarlinsky@gmail.com

2013 July 4th Menemsha Summary Report

Comfort Stations:

- Comfort station usage was at an all time high.
- Comfort station floor drains had clogged and caused flooding. The womans room main floor drain broke and has a rubber boot in its place. Drains have been vacuumed out and cleaned out to avoid future floor flooding.
- Hot water tank had been replaced at the beginning of the season. An electro rod had been replaced over the weekend as water was leaking out of the top.
- Do to the large amount of usage and taxation on the plumbing system it has been suggested that port-o-potties be placed at the front of the beach. This would reduce amount of traffic, wear and tear and water usage on comfort stations. The consensus of the local businesses is in favor of this idea.

Trash:

- As expected a larger amount of trash was collected. The town container was full by Saturday July 6th, and several loads of trash were put in other containers. The cost is estimated to be about \$250 to \$350. I spoke with Don Hatch to let him know.
- The barrels on the beach and near the boats were sometimes completely empty and still there was trash left outside of them.
- This is what one shopping bag of trash left out of empty barrels looks like. I would like thank Marshal Carroll for the collection of litter and debris.





Seth Karlinsky
P.O. Box 546
Chilmark, MA 02535
Phone: 508-645-9310
Cell: 508-455-8615
smithpropertymv@gmail.com
sethkarlinsky@gmail.com

2013 July 4th Menemsha Summary Report

Water Usage:

<i>Date</i>	<i>Reading</i>	<i>Gallons Used</i>
April 15, 2013	238,970	
June 7, 2013	241,170	2200
July 2, 2013	244,446	3276
July 8, 2013	246,250	1804

- July 4th weekend there was \$104 in quarters from the men and women's showers.
 - \$1= 3 minutes
 - \$60 = 90 minutes
 - 90 min x 2.5 gallons per minute = 225 gallons used for showers only
 - 225 gallons divided by 6 days = 37.5 gallons per day
- Toilet water use average:
 - 263 gallons per day / 6 toilets = 43.5GPD per toilet
 - 43.5 GPD / 1.6 gallons per flush = 27.4 flushes per day per toilet

Alternative ideas for cutting down on water usage:

To help reduce water usage for future season's the following is proposed:

Waterless urinals installed.

1.0 GPF power assisted toilets installed

Low flow shower heads installed

www.one2flush.com installed in existing toilets (least expensive) being used currently at Felix Neck Sanctuary

Vandalism /Graffiti /Criminal Activity:

- There were no incidents to report.