

**From:** [Marina Lent](#)  
**To:** [Tim Carroll](#)  
**Subject:** Fwd: Harbor Pumpout  
**Date:** Friday, October 14, 2016 2:31:35 PM

---

Sent from my iPhone

Begin forwarded message:

**From:** Doug Cooper <[coopenv@comcast.net](mailto:coopenv@comcast.net)>  
**Date:** October 14, 2016 at 2:13:33 PM EDT  
**To:** Marina Lent <[boh@chilmarkma.gov](mailto:boh@chilmarkma.gov)>  
**Subject: Re: Harbor Pumpout**

Marina:

This is to confirm my inspection of the harbor pump out facility in Menemsha last month. I met with you and Glenn DiBlase and looked over the pump equipment. We could not detect any odor outdoors or in the harbor master shed. I told Glenn to call me on my cell phone if the situation re occurred. If a broken pipe is suspected ( I saw no evidence of that) a plumber could pressurize the line and do a leak down test. Otherwise, I am at a loss to explain the odor event.

Sent from my iPhone

Please note, my email address has been recently changed. Please update your address book to reflect my new email address: [boh@chilmarkma.gov](mailto:boh@chilmarkma.gov)

Marina Lent  
Board of Health  
Town of Chilmark  
401 Middle Road, PO Box 119  
Chilmark, MA 02535-0119  
(508)645-2105 (ph)  
(508)645-2110 (fax)

The Secretary of State's office has determined that most e-mails to and from municipal offices and officials are public records. Consequently, confidentiality should not be expected.