

## Hydrant

1. Hydrant shall be located no further than 10 feet from a driveway or parking area for Fire Department access at ALL times.
2. Hydrant shall be plumbed with Schedule 80 P.V.C. to bottom drain of pool so that all water is available for fire fighting purposes.
3. Hydrant shall be equipped with a Style 132 Dry Hydrant Male Adapter made of Aluminum Alloy or an equal product from another manufacturer with 4 ½" of National Standard thread.
4. Male Adapter shall be located exactly 40 inches above finish grade.
5. Male Adapter shall have a Style 130 Dry Hydrant Plug with a vinyl coated stainless steel wire rope securing it to the Male Adapter.