



www.souratigroup.com

Martha's Vineyard Office
107 Beach Rd., Suite 202
P.O. Box 4458, Vineyard Haven, MA 02568
Phone: 508-693-9933, Fax: 508-693-4933

Nantucket Office:
35 Old South Road, Nantucket, MA 02554
Phone: 508-228-7888, Fax: 508-228-5511

April 25, 2024

Board of Health
Town of Chilmark
P.O. Box 119
Chilmark, MA 02535

Re: Stephen Kaufman, Trustee of the Marina P. Kaufman Trust
Assessor's Map 11, Parcels 60 & 61
3 Wososket Lane
Chilmark, Massachusetts

Dear Board Members:

The sewage disposal system designed for the above referenced property has been installed.

The installation was performed by John Keene Excavation and was found to be in general compliance with the design plan approved by the Chilmark Board of Health, except for the water line from the well to the house was found to be less than 10' from the leaching field & septic tank.

The owner's would like to relocated the water line 12' away from the septic tank & the leaching field during the upcoming construction of an addition to the house.

An As-Built Sketch is attached for your reference.

Please feel free to contact me if you have any questions.

Sincerely,

A handwritten signature in black ink that reads "George Sourati". The signature is written in a cursive, flowing style.

George Sourati, P.E.

Job# 102451