

WAY

NORTH ROAD

1"=20'

"THE HOME PORT" RESTAURANT

existing enhanced septic - un-vented

PROPOSED 9' W x 17' L x 11' D FAST TANK

(2) 2" P.V.C. FORCE MAINS (SCH. 80)

PROP. DISTRIBUTION BOX (TYP. OF 2)

proposed asphalt cut

Limit of AE flood zone (elevation 12 NAVD)

4'x8' FLOW DIFFUSOR LEACHING CHAMBERS ROTONDO FD 4 x 8S OR EQUAL (56 CHAMBERS IN EACH LEACHING BED)

existing vent pipe

LEACHING BED (TYP. OF 2)

BENCH MARK EL. 12.71'

CB UNDER PAVEMENT



Reid G. Silva
03/18/2024

Notes:

- 1. Site plan information contained on this plan has been obtained for septic system design by Kent Healy
- 2. This plan is for the permitting and installation of a vent pipe to the existing FAST tank.

Sketch Plan
Chilmark, Mass.
Homeport Restaurant
March 18, 2024



VINEYARD
LAND SURVEYING
& ENGINEERING

12 Cournoyer Road
P.O. Box 421
West Tisbury, MA 02575
P 508-693-3774 F 508-629-0440
VLSE.net