

EXHIBIT A

**in support of Opposition of Martha Cottle, Trustee of Cottle Family Realty Trust to
Nixon Variance Proposal as requested in letter from Reid Silva dated December 1, 2021**

<u>Category</u>	<u>Chilmark BOH</u>	<u>Nixon proposal</u>	<u>% deviation proposed by Nixon</u>
Leaching to Wetlands	100'	15'	85%
Leaching to Surface Water	150'	101'	33%
Leaching to Property Line	30'	1-2'	97%-94%
Leaching to Ground Water	5'	4'	20%
Septic to Wetland	50'	8'	84%
Septic to Property Line	10'	1-2'	90%-80%

Avg. Nixon Proposed deviation from Chilmark BOH = 68%

Median Nixon Proposed deviation from Chilmark BOH = 84.5%

<u>Category</u>	<u>MA Title V</u>	<u>Nixon proposal</u>	<u>% deviation proposed by Nixon</u>
Leaching to Wetlands	100'	15'	85%
Leaching to Property Line	30'	1-2'	97%-94%
Leaching to Groundwater	5'	4'	20%
Leaching to Waterline	10'	1'	90%
Septic to Wetland	25'	8'	78%
Septic to Property Line	10'	1-2'	90%-80%

Avg. Nixon Proposed deviation from Title V = 77%

Median Nixon Proposed deviation from Title V = 87.5%