

Kara Shemeth

From: SERO_NOI@MassMail.state.ma.us
Sent: Thursday, May 27, 2021 10:53 AM
To: mark.bartow@mass.gov; reid@vlse.net
Cc: sero_noi@state.ma.us; kshemeth@chilmarkma.gov; sero_noi@state.ma.us
Subject: MassDEP NOI File Number

COMMONWEALTH OF MASSACHUSETTS
EXECUTIVE OFFICE OF ENERGY & ENVIRONMENTAL AFFAIRS
DEPARTMENT OF ENVIRONMENTAL PROTECTION
SOUTHEAST REGIONAL OFFICE
20 RIVERSIDE DRIVE, LAKEVILLE, MA 02347 508-946-2700

Date: 05/27/2021 Municipality CHILMARK

RE: NOTIFICATION OF WETLANDS PROTECTION ACT FILE NUMBER

The Department of Environmental Protection has received a Notice of Intent filed in accordance with the Wetlands Protection Act (M.G.L. c. 131, §40):

Applicant SEAN P. GILDEA Address C/O VLS, PO BOX 421, WEST TISBURY MA Locus 53 WEQUOBSQUE ROAD , CHILMARK MA	Owner Address
---	--------------------------

This project has been assigned the following file # : **SE 012-0873**

ISSUANCE OF A FILE NUMBER INDICATES ONLY COMPLETENESS OF SUBMITTAL, NOT APPROVAL OF APPLICATION

Although a file # is being issued, please note the following:

The NOI should include a narrative describing how the work is to be completed so as to avoid adverse effects on the coastal bank. It should also identify the number of pilings, describe what materials will be used and how they are to be installed. What is the overall length and width of the stairway? The narrative should also quantify any temporary impacts from construction. Is there vegetation in the footprint of the stairway that may be shaded by the structure? The site plan should also include at least one cross section showing the height and width of the stairway.

Regards,
for MassDEP,

(508)-946-2746
Mark.Bartow@mass.gov