


Artesian Relief Line Site Plan Chilmark, Massachusetts

Prepared For

Stephen Merkel & Robin Shanus

Scale: 1" = 40' March 29, 2024

Schofield, Barbini & Hoehn Inc.
Land Surveying & Civil Engineering



12 Surveyor's Lane, Box 339
Vineyard Haven, Mass.
508-693-2781
www.sbhinc.net
MV 8614 (Con Com)

- Notes:
- A. Silt fence to be maintained as shown throughout construction
 - B. Wetlands delineated by Cooper Environmental Services, Inc.
 - C. A pre-construction meeting shall be held between the general contractor and a representative of the Chilmark Conservation Commission prior to start of construction
 - D. All crushed stone to be double-washed
 - E. Underground utilities to be located at start of construction and protect as required
 - F. Existing PVC and ADS pipe to be replaced with 4" PVC in existing alignment.
 - G. **SCHEDULE 80 PVC** to be used below the traveled way of Howell Lane
 - H. Backfill around well casing to be dense mix or approved equal hand compacted in 6" lifts dressed with 4" of seeded topsoil
 - I. Relief line to be pitched to drain to discharge or casing (no "low points")

