



- Notes:**
1. Wetlands delineated by Cooper Environmental Services, Inc.
 2. Service from shored well on Assessor's Parcel 31-6.1 do be disconnected
 3. Proposed well to be staked by Schofield, Barhini, & Hoehn, Inc.
 4. Variances from the Chilmark Board of Health Regulations required:
 - a. Proposed well to property line (Asst. Pct 31-1-1): 10' (30' required)
 - b. Proposed well to locus cesspool: 100' (150' required)
 5. Chilmark Conservation Commission approval is required
 6. Drilling mud and cuttings to be removed from the site at the end of each work day
 7. Silt fence to be maintained as shown throughout drilling, development, and trenching



Locus Map no scale

received
10-11-2022



Well Plan
Chilmark, Mass.
Prepared For
Charles Russell Twist
Scale: 1" = 20'
September 12, 2022
Schofield, Barhini & Hoehn Inc.
Land Surveying & Civil Engineering
12 Surveyor's Lane, Box 339
Vernon, MA 01969
508-893-2781
www.sbhinc.net
MV 11775 (Con Com well)